## **INSPECTION REPORT**

PERMIT NUMBER:	2001-09106	OWNER'S NAME:	SETTLEMIER
DATE:	7/29/2015	TYPE:	Plumbing
TIME STARTED:	2:11 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	21-14-28050-0021		
1. Interior	Structure OK to Cover.		
2. If Plumbing is Modified Partial Plumbing Inspection will be Required.			
3. Deck Framing Framing Not Approved. Drawings Do Not Adequately Depict Deck Framing. Engi			
neering Required.			
4. Deck Footings Appear Compromised. Engineer to Verify Footings. Deck Ledger Not Attached			
INSTRUCTIONS: Make Corrections Above. Submit Engineered Deck Drawings for Revision.			
NEXT INSPECTION: Deck Framing/Deck Footings/Partial Plumbing.			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			