## **INSPECTION REPORT**

TYPE:

BP 13-00558

8/28/2014

**PERMIT NUMBER:** 

DATE:

OWNER'S NAME:

**SANFORD** 

Final

TIME STARTED	: 11:43 AM	INSPECTOR:	Amber Green
MAP NUMBER	20-15-19050-0041		
1. Ha	rdware at garage fire door.	Must be sel	f-closing, self-latching,
2. Complete drywall at lid of laundry area at tankless water heater.			
INSTRUCTIONS	: Complete Above, then Final OK		
NEXT INSPECTI	on: <sub>n/a</sub>		
RE-INSPECTION			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION  QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
amber.green @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			