



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP 14-00152 **OWNER'S NAME:** THOMPSON
DATE: 7/30/2014 **TYPE:** Frame-Plumb-Mech
TIME STARTED: 12:05pm **INSPECTOR:** Jessica Contratto
MAP NUMBER: 17-19-34052-0001

	Gas not on test
	A35s at cantilevered porch roof per detail 3/S5.1
	Stamped truss sheets not on site. Sheets that are stamped are not correct sheets
	Bath fans not complete

INSTRUCTIONS: complete above. ok to insulate. See corrections then. Have truss sheets at insulation inspection

NEXT INSPECTION: insulation

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506