



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-09-00611

OWNER'S NAME: NYHOF

DATE: 8/8/2014

TYPE: Final

TIME STARTED: 2:20

INSPECTOR: Mike Flory

MAP NUMBER: 19-16-24051-0846

	1. HAVE SEPTIC AND ACCESS FINAL COMPLETED
	2. CONNECT HOT WATER PRESSURE RELIEF VALVE TO EXTERIOR STUB OUT IN WALL

INSTRUCTIONS: FINAL OK BUT CANNOT ISSUE CERTIFICATE OF OCCUPANCY UNTIL SEPTIC

NEXT INSPECTION: FINAL INSPECTION OK. C OF O ISSUED AFTER SEPTIC AND ACCESS

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ mike.flory @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506