INSPECTION REPORT

PERMIT NUMBER: BP-11-00441 OWNER'S NAME: THOMPSON

DATE:	6/22/2015	TYPE:	Final
TIME STARTED:	10:10 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-14-35000-0008		
1. Install ve	nt termination on NE side of hou	ıse	
Caulk around exterior cable penetration on N side of garage			
	·		
INSTRUCTIONS: Re-inspection			
NEXT INSPECTION: Re-Inspection			
RE-INSPECTION FEE	DUE? VES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
<u>iustin bennett</u> @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			
· · · · · · · · · · · · · · · · · · ·			