



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-12-00182

OWNER'S NAME: LINDSTROM

DATE: 3/9/2016

TYPE: Final

TIME STARTED: 1:12 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-28052-0007

1. Install returns @ top and bottom of railing
2. Maintain fire separation in West garage @ the ceiling
3. Verify fire door @ studio
4. Smoke/CO Ok
5. Plumbing Ok
6. NOTE: Bring office dwgs for inspection

INSTRUCTIONS: Complete above corrections/Re-Fee/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506