



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00197 OWNER'S NAME: PAUL NW INVESTMENTS  
DATE: 9/19/2014 TYPE: Re-inspection  
TIME STARTED: 11:45 AM INSPECTOR: Amber Green  
MAP NUMBER: 20-15-19051-0071

	1. Steel header and cement board not installed at fireplace per installation manual.
	2. Top clearances not being met.
	3. Draftstop not tight/blocked in at fireplace.

INSTRUCTIONS: Complete Above. OK to cover EXCEPT at fireplace.

NEXT INSPECTION: Fireplace

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506