



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00200 OWNER'S NAME: PAUL NW INVESTMENTS
DATE: 9/19/2014 TYPE: Multiple (see notes)
TIME STARTED: 11:42 AM INSPECTOR: Amber Green
MAP NUMBER: 20-15-19051-0072

	1. Drywall needs to extend from the top plate to the bottom side of the roof sheathing in the attic area.

INSTRUCTIONS: Complete Above, Re-Call Inspection.

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506