KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-13-00246	**OWNER'S NAME:**	SMITH
DATE:	4/8/2015	**TYPE:**	Final
TIME STARTED:	4:38 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	17-19-34000-0035		

	1. Install fire caulking in garage @ openers
	2. Mechanical Ok
	3. Plumbing Ok
	4. Make corrections above and call for re-inspection

INSTRUCTIONS: Fire caulk penetrations in garage/Re-inspection

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____justin.bennett **@co.kittitas.wa.us**