



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00372 OWNER'S NAME: GEYER
DATE: 11/17/2014 TYPE: Final
TIME STARTED: 1:15 PM INSPECTOR: Lou Whitford
MAP NUMBER: 19-20-29051-0004

	1. HANDRAILS MISSING ON HIGH SIDE FRONT PORCH
	2. DRYER VENT CAP MISSING
	3. CAULK AROUND EXTERIOR VENT PIPES
	4. PROVIDE MANUAL FOR STOVE
	5. PERMIT CARD AND PAPERWORK TO BE ON SITE
	6. INSTALL VANITY IN BATHROOM

INSTRUCTIONS:

NEXT INSPECTION: RE-INSP FINAL

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506