



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00413

OWNER'S NAME: DEFOOR

DATE: 12/18/2015

TYPE: Mechanical and plumbir

TIME STARTED: 1:13 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-17-35053-0001

	1. Mechanical OK. Gas Line at 15#/15min.
	2. Plumbing Rough In OK. Supply at 65#/15min. DWV at 5#/15min
	3. Trusses OK.
	4. Framing OK.
	5. Radiant Tubing at 100#/15min.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506