



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00413

OWNER'S NAME: DEFOOR

DATE: 3/21/2016

TYPE: Final

TIME STARTED: 9:05 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-17-35053-0001

1. Septic not finalized
2. Maintain fire separation at garage party wall. Cover exposed ICF foam and treated wood on party wall with sheetrock. Fire caulk gap from sill plate at ceiling along back wall
3. Permit is exempt from WUIC inspection. Permit pulled before implementation

INSTRUCTIONS: Complete above, call for re-inspection

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506