



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00481

OWNER'S NAME: DICKINSON

DATE: 2/1/2016

TYPE: Final

TIME STARTED: 11:12 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-13030-0001

1. Porch Addition Not Constructed Per Plan.
2. NOTE: Homeowners Does Not have a Copy of The Approved Plan. Please Bring Office Copy for Future Inspections.
3. Homeowner Does Not Have Authorizaqtion from L&I Regarding Attachment to Structure.
4. West Roof Posts Do Not Extend to Ground. West Deck Posts SEt in Pier Blocks Not Per Plan.
5. East Roof Posts Set in Ground Not. Depth Not Verified.
6. All Posts 4x4 As-Built. 6x6 Required.

INSTRUCTIONS: Modify Construction to Comply with Approved Drawing. or Obtain L&I and Structural Engineers Approval.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506