



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00628

OWNER'S NAME: MATHESON

DATE: 7/3/2014

TYPE: Final

TIME STARTED: 11:32 AM

INSPECTOR:

	1. Duct leakage test data not recorded on compliance certificate.
	2. Weather strip the crawl access.
	3. Anti-tip at the range.

INSTRUCTIONS: Road certification required for Loping Lane prior to Final Certificate of Occupancy. Provide duct leakage test results.

NEXT INSPECTION: None, just e-mail above.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL

ADDRESS: _____ @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506