

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-13-00703	OWNER'S NAME:	BERTEIG
DATE:	10/10/2014	TYPE:	Shearwalls
TIME STARTED:	9:39 AM	INSPECTOR:	Amber Green
MAP NUMBER:	19-16-02000-0007		

1. No plans or permit on site.		
2. Front wall sheathing not complete.		

INSTRUCTIONS: Your plans and permit must be on site for inspection. Re-Call. DO NOT COVER.

NEXT INSPECTION: EXTERIOR SHEAR

RE-INSPECTION FEE DUE?

V NO

YES

S

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506