



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00703

OWNER'S NAME: BERTEIG

DATE: 2/18/2015

TYPE: Insulation

TIME STARTED: 9:39 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-16-02000-0007

	1. Chose New Energy Credit by Final.
	2. Draft Stop at Basement Fireplace Needs Fire Caulk around Perimeter.
	3. Insulation not Complete at BAsement Fireplace
	4. Upstairs Fireplace Framing Not Complete.
	5. All Other Corrections OK.

INSTRUCTIONS: DO NOT COVER FIREPLACE. Complete Above Corrections. OK to Cover Elsewhere.

NEXT INSPECTION: Fireplace

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506