INSPECTION REPORT

BP-13-00725

PERMIT NUMBER:

OWNER'S NAME: GREER

DATE:		7/28/2014	TYPE:	Re-inspection	
TIME STARTED:		12:44p	INSPECTOR:	Jessica Contratto	
MAP NUMBER:		18-20-03000-0007			
	H2O is liv	H2O is live			
	DWV at 6#-OK				
INSTRUCTIONS: Send engineer approval for retrofit hold down.					
NEXT INSPECTION: frame/mechanical, geothermal lines, hydronic					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	jessica.contratto @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •					
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506					