



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00725

OWNER'S NAME: GREER

DATE: 10/15/2014

TYPE: Re-inspection

TIME STARTED: 11:25

INSPECTOR: Lou Whitford

MAP NUMBER: 18-20-03000-0007

	1. ITEM #3 IS STILL OUTSTANDING. MUST FIX PRIOR TO COVER
	2. OK GAS TEST 8#S/20 MINUTES

INSTRUCTIONS: A RE-FEE OF \$65.00 WILL BE IMPOSED IF YOU DO NOT PASS NEXT INSPECTION.

NEXT INSPECTION: RE-INSPECTION OF CHIMNEY FLASHING AT ROOF.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506