



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00725 OWNER'S NAME: GREER-STEINBACH
DATE: 7/9/2015 TYPE: Final
TIME STARTED: 4:11 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 18-20-03000-0007

	1. Drywall Required on Mechanical Lid per Drawing.
	2. Provide Flame/Smoke Spread Index for Foam insulation on Mechanical Walls.

INSTRUCTIONS: Make Corrections Above

NEXT INSPECTION: Re Inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506