



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00734

OWNER'S NAME: EATON

DATE: 11/25/2015

TYPE: Natural gas

TIME STARTED: 2:07 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-19-300000-0022

	1. Gas Line OK. 15#/15min.
	2. Shear Correction OK.

INSTRUCTIONS: Refill Gas Line to Required PSI. Then Call for ReInspection.

NEXT INSPECTION: Plumbing/Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506