



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00813

OWNER'S NAME: BARBER

DATE: 4/2/2015

TYPE: Stove or fireplace

TIME STARTED: 10:53 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-19-32030-0003

	1. Foam Insulation Connect Exterior Chimney with Wall Sheeting Not Acceptable. Remove Foam
	.
	2. 1" Separation to Combustible Material Required.
	3. Seismic Rebar In Chimney OKd.
	4. Mantle Not Approved per Prescriptive Requirement. Final Stove Selection May Allow.

INSTRUCTIONS: Complete Above.

NEXT INSPECTION: Re Inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506