INSPECTION REPORT

TYPE:

PERMIT NUMBER:

DATE:

BP-14-00049

7/28/2014

OWNER'S NAME: VALLEY VET/HAYDEN

Footings

TIME STARTED:		INSPECTOR	 Jessica Contratto
MAP NUMBER:	17-19-06020-0002		
ramp retaining wall and footings- OK to pour			
INSTRUCTIONS	 Finish adding horizontal rebar to very pour after completed 	vall. 3 total.	finish 2nd layer of bar in footing. Ok to
	pour anor completed		
NEXT INSPECTION	ON:		
RE-INSPECTION	FEE DUE? NO YES	3	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jessica.contratto @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			
1			