INSPECTION REPORT

BP-14-00049

PERMIT NUMBER:

OWNER'S NAME: HAYDEN

DATE:	11/10/2014	TYPE:	Multiple (see notes)
TIME STARTED:	4:10 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	17-19-06020-0002		
1. wall insulation ok			
2. windows .26 u factor			
INSTRUCTIONS: ok to cover walls			
NEXT INSPECTION: vault ceiling insulation			
RE-INSPECTION FEE	DUE? NO YES	<u> </u>	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jessica.contratto @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 			