



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00052

OWNER'S NAME: GORE

DATE: 8/19/2014

TYPE: Gas piping

TIME STARTED: 1:06 PM

INSPECTOR: Amber Green

MAP NUMBER: 20-15-19050-0110

	1. Gas piping pressure test too low : must be a minimum of 15 psi.
	2. Gas pipe cannot enter or exit through the foundation wall below grade.

INSTRUCTIONS: Complete/fix above, re-call inspection.

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506