



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00063

OWNER'S NAME: MANASTASH RIDGE E

DATE: 9/24/2015

TYPE: Rough-in plumbing

TIME STARTED: 9:58 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-18010-0015

	1. Permitted Set Plans Required for Inspection.
	2. Plumbing Supply Not On Test, Guage Reads 0#
	3. DWV Not Able to Determine Test Pressure, No Guage.
	4. Mechanical Systems Not Inspected. Mechanical Inspection Required Prior to Framing.

INSTRUCTIONS: Make Corrections Above.

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506