



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00063

OWNER'S NAME: MANASTASH RIDGE

DATE: 10/6/2015

TYPE: Plumbing

TIME STARTED: 2:14 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-18010-0015

	1. DWV on Stack Test.
	2. Supply at 90#/15min.
	3. Plumbing Rough OK.

INSTRUCTIONS:

NEXT INSPECTION: Mech/Framing

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506