



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00064

OWNER'S NAME: MANASTASH RIDGE E

DATE: 9/24/2015

TYPE: Rough-in plumbing

TIME STARTED: 10:05 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-18010-0003

	1. Mechanical Inspection Not Completed.
	2. Approved Drawings Required for Inspection.
	3. DWV Not On Test. Gauge Reads 0#.
	4. Supply OK. 70#/15min.

INSTRUCTIONS: MAke Corrections Above.

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506