



KITTTAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-14-00064                      OWNER'S NAME: MANASTASH RIDGE  
 DATE: 10/6/2015                                      TYPE: Plumbing  
 TIME STARTED: 10:50 AM                              INSPECTOR: Jeremy Haberman  
 MAP NUMBER: 17-18-18010-0003

1. Rough Plumbing OK.
2. Supply at 70#/15min. OK
3. DWV at 6#/15min. OK.
4. Address Not Visible/Posted??
5. Plans/Permit Not On Site.
6. Mechanical Venting Not Complete.
7. Confirm Floorplan and Intended Use of Structure at Framing Inspection.

**INSTRUCTIONS:** Call for Mechanical/Framing Inspection.

**NEXT INSPECTION:** Mech/Framing

RE-INSPECTION FEE DUE?     NO     YES    \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506