INSPECTION REPORT

PERMIT NUMBER: BP-14-00087 OWNER'S NAME: NEW SUNCADIA LLC

DATE:		7/9/2014	TYPE:	Framing and plumbing	
TIME STARTED:		2:32 PM	INSPECTOR	R:	
	Add wedge bearing block at rafters to top plate.				
	DWV (H	20/15min) : OK			
	Water li	nes : working pr	essure		
INSTRUCTIONS: OK to Insulate					
NEXT	INSPECTION:	Insulation			
RE-IN	SPECTION FEE	DUE? NO	YES	\$	
	IF REC	QUIRED, RE-INSPECTION	FEES MUST BE PAID PRIOR	TO SCHEDULING A RE-INSPECTION	
		QUESTIONS? PLEASE ADDRESS:	CONTACT THE INSPECTOR A	TTHE FOLLOWING E-MAIL@co.kittitas.wa.us	
				ds/request.asp or 509-962-7694 • Main Office Line: 509-962-7506	