



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00095 OWNER'S NAME: TILTON
DATE: 8/22/2014 TYPE: Exterior shear
TIME STARTED: 1:06 PM INSPECTOR: Amber Green
MAP NUMBER: 17-19-02077-0003

	1. Sill plate nailing at the garage shear panels.
	2. Nails into pressure treated wood to be hot dipped galvanized.
	3. Double sill plate on plans at portal frame walls at garage per 5/D1

INSTRUCTIONS: Complete #1 and #2. Obtain OK from engineer for #3. Re-call inspection.

NEXT INSPECTION: Re-Shear

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:
amber.green @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506