



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-14-00095      OWNER'S NAME: TILTON  
DATE: 9/15/2014      TYPE: Frame-Plumb-Mech  
TIME STARTED: 1:57 PM      INSPECTOR: Jessica Contratto  
MAP NUMBER: 17-19-02077-0003

	1. Sheetrock needed behind furnace
	2. DWV not on test
	3. H2O at 100#-ok
	4. bath fans not completed, see by insulation
	5. gas piping not in
	6. truss bracing on truss B missing
	7. need to verify bracing on trusses in porch overhang. Have ladder available
	8. chimney not complete for fireplace

INSTRUCTIONS: complete above, call for re-inspection

NEXT INSPECTION: re-inspection

RE-INSPECTION FEE DUE?     NO     YES    \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506