



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00095
DATE: 9/24/2014
TIME STARTED: 11:01 AM
MAP NUMBER: 17-19-02077-0003

OWNER'S NAME: TILTON
TYPE: Insulation
INSPECTOR: Jessica Contratto

1. DWV at 6#-ok
2. check on engineer approval for trimming truss tails above front door
3. R-19 insulation used behind jetted tub and shower enclosure.
4. nail shower flanges

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506