



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-14-00095      OWNER'S NAME: TILTON  
 DATE: 2/17/2015      TYPE: Final  
 TIME STARTED: 11:11 AM      INSPECTOR: Justin Bennett  
 MAP NUMBER: 17-19-02077-0003

1. Fireplace not operating
2. Plumbing drain leak in hall bathroom
3. Blow door test not in ACH
4. Install elbow at condensate drain at rear deck
5. Permit card not on site
6. Provide access and septic approval

**INSTRUCTIONS:** Make corrections above and call for reinspection with permit card on site

**NEXT INSPECTION:** Reinspection

RE-INSPECTION FEE DUE?     NO     YES    \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506