INSPECTION REPORT

TYPE:

PERMIT NUMBER:

DATE:

BP-14-00095

2/18/2015

OWNER'S NAME:

TILTON

Re-inspection

TIME STAR	TED:	12:34 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:		17-19-02077-0003		
1. Fireplace is not operational				
2.	2. Blower door report has not be received			
INSTRUCTIONS: Complete items above and call for reinspection				
NEXT INSPECTION: Reinspection				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
justin.bennett @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 				