## **INSPECTION REPORT**

PERMIT NUMBER:	BP-14-00140	OWNER'S NAME:	WOODRIDGE CUSTOM HOMES
DATE:	10/15/2014	TYPE:	Framing and mechanical
TIME STARTED:	11:33 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-29051-0025		
1. engineer approval for change in upstairs bedroom. added window			
2. gas not on test			
3. insulation guard at main fireplace			
4. windows to be u-value of .28. May need to change energy credit option			
INSTRUCTIONS: see gas on test at insulation, and check bedroom changes			
NEXT INSPECTION: gas, insulation			
RE-INSPECTION FEE I	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jessica.contratto @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •			