



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00140 OWNER'S NAME: WOODRIDGE CUSTOM
DATE: 11/4/2014 TYPE: Insulation
TIME STARTED: 12:03 PM INSPECTOR: Lou Whitford
MAP NUMBER: 20-15-29051-0025

	1. STILL PENDING ENG LETTER FOR CHANGE / ADDED WINDOW
	2. SPRAY FOAM INSULATION AT BEDROOM FIRE PLC TO BE CUT BACK/PROTECT
	3. WINDOWS MISSING STICKERS TO MEET OTION 1a OF .28 U-VALUE
	4. PROVIDE INVOICE FOR GLAZING COMPLIANCE
	5. OK GAS TEST 30#S/ 20 MINUTES

INSTRUCTIONS: PARTIAL COVER OK- DO NOT COVER BEDRM FIREPLACE. PROVIDE WINDOW INVOICE.

NEXT INSPECTION: FIRE PLACE CLERANCE INSPECTION

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506