



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00140 OWNER'S NAME: WOODRIDGE
DATE: 3/5/2015 TYPE: Final
TIME STARTED: 11:02 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-29051-0025

	1. Exterior Door at Mother In Law Not Weather Tight.
	2. Garage to Mother In Law/Garage to MAIn House not Self Closing.
	3. Panel Covers Not Installed.
	4. Garage to Mother In Law/Garage to Main House Doors Missing Hardware. Fire Seperation No
	t Complete.
	5. Various Electric Outlets Not Installed/Not Trimmed.
	6. Crawl Access Door Requires Insulation/Weatherstrip
	7. Energy Credit Not Met for 2A. Efficient Ventilation.

INSTRUCTIONS: Complete Above

NEXT INSPECTION: Reinspect

RE-INSPECTION FEE DUE?

☒ NO

☐ YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506