INSPECTION REPORT

PERMIT NUMBER:	BP-14-00173	OWNER'S NAME:	THE PASS LLC
DATE:	2/20/2015	TYPE:	Final
TIME STARTED:	10:37 AM	INSPECTOR:	Amber Green
MAP NUMBER:	22-11-04055-0032		
Install fire rated man door at garage.			
2. Complete second layer of drywall at firewall in garage.			
3. Verify propane supply/function to range.			
INSTRUCTIONS: Complete Above, call for Re-inspection.			
NEXT INSPECTION: Re-Inspection			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
amber.green @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2. Ellensburg, WA 98926 • Main Office Line: 509-962-7506			