



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00223 OWNER'S NAME: PQD CONSTRUCTION
DATE: 7/24/2014 TYPE: Plumbing
TIME STARTED: 3:47 PM INSPECTOR: Jessica Contratto
MAP NUMBER: 20-14-12065-0001

	(2) SDS screws at 16" on center on deck ledger
	post down to foundation at point loads per plan note
	DWV on stack-OK
	H2O at 52#- OK
	gas at 15#-OK
	Provide letter for heel cut on BCI rafters in upstairs
	plumb/mech OK
	range exhaust needs to be 6" to carry min. of 100CFM

INSTRUCTIONS: complete above. see at insulation

NEXT INSPECTION: insulation

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506