



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00249

OWNER'S NAME: BODENMAN

DATE: 10/1/2014

TYPE: Frame-Plumb-Mech

TIME STARTED: 10:44 AM

INSPECTOR: Amber Green

MAP NUMBER: 17-18-05050-0002

	1. DWV (5#/15min) - OK
	2. H2O (80#/15min) - OK
	3. Complete range vent - will see at final.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [amber.green@co.kittitas.wa.us](mailto:amber.green@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506