



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00258

OWNER'S NAME: PDQ CONSTRUCTION

DATE: 7/29/2014

TYPE: Insulation

TIME STARTED:

INSPECTOR: Amber Green

MAP NUMBER: 20-14-12067-0005

	1. Complete vapor barrier at insulated walls at fireplace corner.
	* Assuming garage is uninsulated

INSTRUCTIONS: Complete Above, then ok to cover.

NEXT INSPECTION: Frame-Plumb-Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506