



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00258 OWNER'S NAME: PDQ CONSTRUCTION  
DATE: 11/4/2014 TYPE: Frame-Plumb-Mech  
TIME STARTED: 2:05 PM INSPECTOR: Lou Whitford  
MAP NUMBER: 20-14-12067-0005

	1. OK DWV STACK TEST 20 MINUTES
	2. OK H2O SUPPLY 60#S 20 MINUTES
	3. OK GAS TEST 18#S 20 MINUTES
	4. OK MECHANICAL ROUGH-IN
	5. OK FIRE PLACE ROUGH-IN
	6. OK FRAMING AND TRUSSES
	7. OK TO INSULATE

### INSTRUCTIONS:

NEXT INSPECTION: INSULATION

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506