INSPECTION REPORT

BP-14-00279

PERMIT NUMBER:

OWNER'S NAME: COONS

DATE:		7/29/2014	TYPE:	Insulation	
TIME STARTED:			INSPECTOR:	Amber Green	
MAP NUMBER:		20-16-34061-00	14		
	Complete voids in upper floor walls.				
	2. Complete vapor barrier throughout.				
	3. No plans and no permit on site.				
	Previous corrections - OK				
INSTRUCTIONS: Complete Above, then OK TO COVER					
NEXT INSPECTION: FINAL					
RE-INSPECTION FEE DUE? NO YES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	amber.green @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 					