



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00301 OWNER'S NAME: SUNRIDGE RANCH II
DATE: 2/13/2015 TYPE: Final
TIME STARTED: 12:47 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 16-19-12000-0010

	1. Plumbing Final OK.
	2. Access Final OK.
	3. Mechanical Final OK.
	4. Insulation Final OK.
	5. Carbon Monoxide Detector Required in Bedroom Adjacent Hallway

INSTRUCTIONS: Install CO Detector

NEXT INSPECTION: Re Inspect.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506