



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00340

OWNER'S NAME: HANSON

DATE: 4/17/2015

TYPE: Mechanical and plumbing

TIME STARTED: 8:54 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-08000-0022

	1. Fireplace OK. Draftstop OK.
	2. DWV OK. 6#/15min.
	3. Supply OK. 65#/15min.
	4. Mechanical OK.
	5. Plumbing OK.
	6. Windows Not Vented. Ventilation Requirement Not Met. Consider Ventilation Option 2 on V
	entilation Worksheet.
	7. Gas Line OK. 15#/15min.

INSTRUCTIONS:

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506