INSPECTION REPORT

PERMIT NUMBER:	BP-14-00340	OWNER'S NAME:	HANSEN
DATE:	4/22/2015	TYPE:	Framing
TIME 674 D75D	,		Justin Bennett
TIME STARTED:	9:04 AM	INSPECTOR:	Justin Dennett
MAP NUMBER:	17-18-08000-0022		
Provide bracing on E9 trusses per truss sheets			
2. Replace closet stud in Bedroom 3			
3. Egress window in Bedroom 2 is swapped			
4. Mechanical Ok			
5. Ok to insulate			
INSTRUCTIONS: Make corrections above/Ok to insulate			
NEXT INSPECTION: Insulation			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
justin.bennett @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			