



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00382 OWNER'S NAME: BRAIN
DATE: 11/17/2014 TYPE: Insulation
TIME STARTED: 9:47 AM INSPECTOR: Lou Whitford
MAP NUMBER: 18-18-36077-0006

	1. DRYER VENT IS NOT IN AT THIS TIME
	2. GAS GAUGE WAS FROZEN??? IT WOULD NOT BLEED. CHECK GAUGE
	3. DID NOT ADHERE TO OPTION 1a OF THE ENERGY CODE.
	4. RESUBMIT NEW ENERGY CALCS TO REFLECT COMPLIANCE AND OTIONS
	5. OK TRUSSES
	6. OK SUPPORT HEAT VENTS

INSTRUCTIONS: DO NOT COVER WALLS WITH GAS PIPE. OK TO COVER ALL OTHER WALLS

NEXT INSPECTION: RE-INSP GAS GAUGE/ DRYER VENT/ENERGY CREDITS

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506