



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00407

OWNER'S NAME: SCHULTEK

DATE: 6/12/2015

TYPE: Final

TIME STARTED: 3:10 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 22-11-09011-0032

	1. sheetrock garage wall
	2. sheetrock any exposed framing on garage walls
	3. seal all penetrations in fire separation- 26ga metal, fire caulk, or drywall mud
	4. provide hot tub cover that meets ASTM F 1346

INSTRUCTIONS: complete above, call for re-inspection

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506