



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00421

OWNER'S NAME: SFAY LLC

DATE: 2/4/2015

TYPE: Mechanical and plumbing

TIME STARTED: 12:52 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0142

	1. Waste on Stack - Ok
	2. Water @ 80#/15 mins - Ok
	3. Mechanical Ok
	4. Install insulation and vapor barrier behind second floor tub

INSTRUCTIONS: Complete draft stop at fireplace

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506