## **INSPECTION REPORT**

**PERMIT NUMBER:** 

BP-14-00428

**OWNER'S NAME:** 

**BUSHNELL** 

DATE:		1/9/2015	TYPE:	Rough-in plumbing	
TIME STARTED:		2:33 PM	INSPECTOR:	Amber Green	
MAP NUMBER:		17-19-13050-00	04		
	1. DWV Plumbing on test. Verified 6 PSI. Supply plumbing on test. Verified 90 PSI.				
	2. Plumbing in basement not included on permit.				
INSTRUCTIONS: Submit revisions prior to framing inspection.					
NEXT INSPECTION: Framing/Mech.					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	amber.green @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926</li> <li>Main Office Line: 509-962-7506</li> </ul>					